



## Potable Water Risk Analysis Summary for the period 2020-02-01 to 2020-02-29 according to SANS 241 - 2015

As on 7 April 2020

	NAME	DESCRIPTION	No.ANALYSIS	No.Compliant Analysis	% COMPLIANCE	EXPLANATION
1.	Drinking Water Quality Compliance	Acute Health Microbiological Compliance (AHMC)	388	384	98.97	Good
2.	Drinking Water Quality Compliance	Acute Health Chemical Compliance (AHCC)	92	92	100.00	Excellent
3.	Drinking Water Quality Compliance	Chronic Health Chemical Compliance (CHCC)	1 063	1 063	100.00	Excellent
4.	Drinking Water Quality Compliance	Operational Compliance (ORC)	1 561	1 551	99.36	Excellent
5.	Drinking Water Quality Compliance	Aesthetic Compliance (AC)	576	576	100.00	Excellent

