



## Potable Water Risk Analysis Summary for the period 2018-03-01 to 2018-03-31 according to SANS 241 - 2015

As on 24 April 2018

	NAME	DESCRIPTION	No.ANALYSIS	No.Compliant Analysis	% COMPLIANCE	EXPLANATION
1.	Drinking Water Quality Compliance	Acute Health Microbiological Compliance (AHMC)	420	405	96.43	Unacceptable
2.	Drinking Water Quality Compliance	Acute Health Chemical Compliance (AHCC)	96	96	100.00	Excellent
3.	Drinking Water Quality Compliance	Chronic Health Chemical Compliance (CHCC)	1 133	1 133	100.00	Excellent
4.	Drinking Water Quality Compliance	Operational Compliance (ORC)	1 598	1 580	98.87	Excellent
5.	Drinking Water Quality Compliance	Aesthetic Compliance (AC)	569	569	100.00	Excellent

