



CITY OF EKURHULENI

Potable Water Risk Analysis Summary for the period 2021-12-01 to 2021-12-31 according to SANS 241 - 2015

As on 27 January 2022

	NAME	DESCRIPTION	No.ANALYSIS	No.Compliant Analysis	% COMPLIANCE	EXPLANATION
1.	Drinking Water Quality Compliance	Acute Health Microbiological Compliance (AHMC)	431	427	99.07	Excellent
2.	Drinking Water Quality Compliance	Acute Health Chemical Compliance (AHCC)	72	72	100.00	Excellent
3.	Drinking Water Quality Compliance	Chronic Health Chemical Compliance (CHCC)	1 156	1 156	100.00	Excellent
4.	Drinking Water Quality Compliance	Operational Compliance (ORC)	1 701	1 670	98.18	Excellent
5.	Drinking Water Quality Compliance	Aesthetic Compliance (AC)	704	701	99.57	Excellent
6.	Drinking Water Quality Compliance	Residual Disinfectant (RD)	430	422	98.14	Excellent

