



CITY OF EKURHULENI

Potable Water Risk Analysis Summary for the period 2021-02-01 to 2021-02-28 according to SANS 241 - 2015

As on 6 April 2021

	NAME	DESCRIPTION	No.ANALYSIS	No.Compliant Analysis	% COMPLIANCE	EXPLANATION
1.	Drinking Water Quality Compliance	Acute Health Microbiological Compliance (AHMC)	400	394	98.50	Good
2.	Drinking Water Quality Compliance	Acute Health Chemical Compliance (AHCC)	64	64	100.00	Excellent
3.	Drinking Water Quality Compliance	Chronic Health Chemical Compliance (CHCC)	1 051	1 051	100.00	Excellent
4.	Drinking Water Quality Compliance	Operational Compliance (ORC)	1 578	1 518	96.20	Excellent
5.	Drinking Water Quality Compliance	Aesthetic Compliance (AC)	617	616	99.84	Excellent

