



CITY OF EKURHULENI

Potable Water Risk Analysis Summary for the period 2022-02-01 to 2022-02-28 according to SANS 241 - 2015

As on 30 March 2022

	NAME	DESCRIPTION	No.ANALYSIS	No.Compliant Analysis	% COMPLIANCE	EXPLANATION
1.	Drinking Water Quality Compliance	Acute Health Microbiological Compliance (AHMC)	405	400	98.77	Good
2.	Drinking Water Quality Compliance	Acute Health Chemical Compliance (AHCC)	68	68	100.00	Excellent
3.	Drinking Water Quality Compliance	Chronic Health Chemical Compliance (CHCC)	1 082	1 081	99.91	Excellent
4.	Drinking Water Quality Compliance	Operational Compliance (ORC)	1 607	1 581	98.38	Excellent
5.	Drinking Water Quality Compliance	Aesthetic Compliance (AC)	653	653	100.00	Excellent
6.	Drinking Water Quality Compliance	Residual Disinfectant (RD)	405	396	97.78	Excellent

