



CITY OF EKURHULENI

Potable Water Risk Analysis Summary for the period 2022-01-01 to 2022-01-31 according to SANS 241 - 2015

As on 23 February 2022

	NAME	DESCRIPTION	No.ANALYSIS	No.Compliant Analysis	% COMPLIANCE	EXPLANATION
1.	Drinking Water Quality Compliance	Acute Health Microbiological Compliance (AHMC)	429	428	99.77	Excellent
2.	Drinking Water Quality Compliance	Acute Health Chemical Compliance (AHCC)	81	81	100.00	Excellent
3.	Drinking Water Quality Compliance	Chronic Health Chemical Compliance (CHCC)	1 175	1 175	100.00	Excellent
4.	Drinking Water Quality Compliance	Operational Compliance (ORC)	1 712	1 684	98.36	Excellent
5.	Drinking Water Quality Compliance	Aesthetic Compliance (AC)	710	708	99.72	Excellent
6.	Drinking Water Quality Compliance	Residual Disinfectant (RD)	428	417	97.43	Excellent

