



CITY OF EKURHULENI

Potable Water Risk Analysis Summary for the period 2022-06-01 to 2022-06-30 according to SANS 241 - 2015

As on 1 August 2022

	NAME	DESCRIPTION	No.ANALYSIS	No.Compliant Analysis	% COMPLIANCE	EXPLANATION
1.	Drinking Water Quality Compliance	Acute Health Microbiological Compliance (AHMC)	418	418	100.00	Excellent
2.	Drinking Water Quality Compliance	Acute Health Chemical Compliance (AHCC)	76	76	100.00	Excellent
3.	Drinking Water Quality Compliance	Chronic Health Chemical Compliance (CHCC)	1 128	1 128	100.00	Excellent
4.	Drinking Water Quality Compliance	Operational Compliance (ORC)	1 676	1 661	99.11	Excellent
5.	Drinking Water Quality Compliance	Aesthetic Compliance (AC)	675	675	100.00	Excellent
6.	Drinking Water Quality Compliance	Residual Disinfectant (RD)	419	416	99.28	Excellent

