



CITY OF EKURHULENI

Potable Water Risk Analysis Summary for the period 2022-09-01 to 2022-09-30 according to SANS 241 - 2015

As on 3 November 2022

	NAME	DESCRIPTION	No.ANALYSIS	No.Compliant Analysis	% COMPLIANCE	EXPLANATION
1.	Drinking Water Quality Compliance	Acute Health Microbiological Compliance (AHMC)	417	416	99.76	Excellent
2.	Drinking Water Quality Compliance	Acute Health Chemical Compliance (AHCC)	84	84	100.00	Excellent
3.	Drinking Water Quality Compliance	Chronic Health Chemical Compliance (CHCC)	1 136	1 136	100.00	Excellent
4.	Drinking Water Quality Compliance	Operational Compliance (ORC)	1 651	1 635	99.03	Excellent
5.	Drinking Water Quality Compliance	Aesthetic Compliance (AC)	660	658	99.70	Excellent
6.	Drinking Water Quality Compliance	Residual Disinfectant (RD)	418	418	100.00	Excellent

