



CITY OF EKURHULENI

Potable Water Risk Analysis Summary for the period 2022-11-01 to 2022-11-30 according to SANS 241 - 2015

As on 3 January 2023

	NAME	DESCRIPTION	No.ANALYSIS	No.Compliant Analysis	% COMPLIANCE	EXPLANATION
1.	Drinking Water Quality Compliance	Acute Health Microbiological Compliance (AHMC)	408	408	100.00	Excellent
2.	Drinking Water Quality Compliance	Acute Health Chemical Compliance (AHCC)	80	80	100.00	Excellent
3.	Drinking Water Quality Compliance	Chronic Health Chemical Compliance (CHCC)	1 106	1 105	99.91	Excellent
4.	Drinking Water Quality Compliance	Operational Compliance (ORC)	1 618	1 596	98.64	Excellent
5.	Drinking Water Quality Compliance	Aesthetic Compliance (AC)	622	620	99.68	Excellent
6.	Drinking Water Quality Compliance	Residual Disinfectant (RD)	413	407	98.55	Excellent

