



City Of Ekurhuleni

Potable Water Risk Analysis Summary for the period 2024-07-01 to 2024-07-31 according to SANS 241 - 2015

As on 28 August 2024

	NAME	DESCRIPTION	No.ANALYSIS	No.Compliant Analysis	% COMPLIANCE	EXPLANATION
1.	Drinking Water Quality Compliance	Acute Health Microbiological Compliance (AHMC)	429	429	100.00	Excellent
2.	Drinking Water Quality Compliance	Acute Health Chemical Compliance (AHCC)	97	97	100.00	Excellent
3.	Drinking Water Quality Compliance	Chronic Health Chemical Compliance (CHCC)	1 221	1 221	100.00	Excellent
4.	Drinking Water Quality Compliance	Operational Compliance (ORC)	1 735	1 725	99.42	Excellent
5.	Drinking Water Quality Compliance	Aesthetic Compliance (AC)	733	733	100.00	Excellent
6.	Drinking Water Quality Compliance	Residual Disinfectant (RD)	432	426	98.61	Excellent

