



City Of Ekurhuleni

Potable Water Risk Analysis Summary for the period 2025-09-01 to 2025-09-30 according to SANS 241 - 2015

As on 23 October 2025

	NAME	DESCRIPTION	No.ANALYSIS	No.Compliant Analysis	% COMPLIANCE	EXPLANATION
1.	Drinking Water Quality Compliance	Acute Health Microbiological Compliance (AHMC)	429	428	99.77	Excellent
2.	Drinking Water Quality Compliance	Acute Health Chemical Compliance (AHCC)	96	96	100.00	Excellent
3.	Drinking Water Quality Compliance	Chronic Health Chemical Compliance (CHCC)	1 218	1 218	100.00	Excellent
4.	Drinking Water Quality Compliance	Operational Compliance (ORC)	1 743	1 729	99.20	Excellent
5.	Drinking Water Quality Compliance	Aesthetic Compliance (AC)	733	732	99.86	Excellent
6.	Drinking Water Quality Compliance	Residual Disinfectant (RD)	435	430	98.85	Excellent

