



City Of Ekurhuleni

Potable Water Risk Analysis Summary for the period 2026-03-01 to 2026-03-31 according to SANS 241 - 2015

As on 11 May 2026

	NAME	DESCRIPTION	No.ANALYSIS	No.Compliant Analysis	% COMPLIANCE	EXPLANATION
1.	Drinking Water Quality Compliance	Acute Health Microbiological Compliance (AHMC)	489	477	97.55	Good
2.	Drinking Water Quality Compliance	Acute Health Chemical Compliance (AHCC)	92	92	100.00	Excellent
3.	Drinking Water Quality Compliance	Chronic Health Chemical Compliance (CHCC)	1 348	1 347	99.93	Excellent
4.	Drinking Water Quality Compliance	Operational Compliance (ORC)	1 907	1 864	97.75	Excellent
5.	Drinking Water Quality Compliance	Aesthetic Compliance (AC)	782	780	99.74	Excellent
6.	Drinking Water Quality Compliance	Residual Disinfectant (RD)	497	485	97.59	Excellent

